

**Iowa Department of Natural Resources  
Title V Operating Permit**

**Name of Permitted Facility: Central Iowa Power Cooperative –  
Summit Lake Facility Generating Station**

**Facility Location: 1632 REA Road, Creston, Iowa 50801**

**Air Quality Operating Permit Number: 99-TV-003R4**

**Expiration Date: 03/16/2027**

**Permit Renewal Application Deadline: 09/16/2026**

**EIQ Number: 92-0871**

**Facility File Number: 88-01-004**

---

**Responsible Official**

**Name: Mr. Rex Butler**

**Title: Manager of Environmental & Safety**

**Mailing Address: 2600 Grand Avenue, Des Moines, IA 50312**

**Phone #: (515) 362-7651**

**E-mail: rex.butler@cipco.net**

**Permit Contact Person for the Facility**

**Name: Mr. Pat Madison**

**Title: Plant Superintendent**

**Mailing Address: 1632 REA Road, Creston, Iowa 50801**

**Phone #: (641) 782-2158**

---

This permit is issued in accordance with 567 Iowa Administrative Code Chapter 22, and is issued subject to the terms and conditions contained in this permit.

**For the Director of the Department of Natural Resources**



03/17/2022

---

Marnie Stein, Supervisor of Air Operating Permits Section

Date

# Table of Contents

<b>I. Facility Description and Equipment List .....</b>	<b>4</b>
<b>II. Plant - Wide Conditions.....</b>	<b>5</b>
<b>III. Emission Point Specific Conditions .....</b>	<b>7</b>
<b>IV. General Conditions.....</b>	<b>27</b>
G1.Duty to Comply	
G2.Permit Expiration	
G3.Certification Requirement for Title V Related Documents	
G4.Annual Compliance Certification	
G5.Semi-Annual Monitoring Report	
G6.Annual Fee	
G7.Inspection of Premises, Records, Equipment, Methods and Discharges	
G8.Duty to Provide Information	
G9.General Maintenance and Repair Duties	
G10. Recordkeeping Requirements for Compliance Monitoring	
G11. Evidence used in establishing that a violation has or is occurring.	
G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification	
G13. Hazardous Release	
G14. Excess Emissions and Excess Emissions Reporting Requirements	
G15. Permit Deviation Reporting Requirements	
G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations	
G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification	
G18. Duty to Modify a Title V Permit	
G19. Duty to Obtain Construction Permits	
G20. Asbestos	
G21. Open Burning	
G22. Acid Rain (Title IV) Emissions Allowances	
G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements	
G24. Permit Reopenings	
G25. Permit Shield	
G26. Severability	
G27. Property Rights	
G28. Transferability	
G29. Disclaimer	
G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification	
G31. Prevention of Air Pollution Emergency Episodes	
G32. Contacts List	
<b>V. Appendix: .....</b>	<b>42</b>

## Abbreviations

acfm.....	actual cubic feet per minute
CFR.....	Code of Federal Regulation
CE .....	control equipment
CEM.....	continuous emission monitor
°F.....	degrees Fahrenheit
EIQ.....	emissions inventory questionnaire
EP.....	emission point
EU .....	emission unit
gr./dscf .....	grains per dry standard cubic foot
gr./100 cf.....	grains per one hundred cubic feet
IAC.....	Iowa Administrative Code
IDNR.....	Iowa Department of Natural Resources
MVAC.....	motor vehicle air conditioner
NAICS.....	North American Industry Classification System
NSPS .....	new source performance standard
NESHAP .....	National Emission Standards for Hazardous Air Pollutants
ppmv .....	parts per million by volume
lb./hr.....	pounds per hour
lb./MMBtu .....	pounds per million British thermal units
SCC .....	Source Classification Codes
scfm.....	standard cubic feet per minute
SIC .....	Standard Industrial Classification
TPY .....	tons per year
USEPA.....	United States Environmental Protection Agency

## Pollutants

PM.....	particulate matter
PM <sub>10</sub> .....	particulate matter ten microns or less in diameter
SO <sub>2</sub> .....	sulfur dioxide
NO <sub>x</sub> .....	nitrogen oxides
VOC .....	volatile organic compound
CO .....	carbon monoxide
HAP.....	hazardous air pollutant

# I. Facility Description and Equipment List

Facility Name: Central Iowa Power Cooperative – Summit Lake Facility Generating Station  
Permit Number: 99-TV-003R4

Facility Description: Electric Service (SIC 4911)

## Equipment List

Emission Point Number	Emission Unit Number	Emission Unit Description	IDNR Construction Permit Number
EP-3	EU-1	Combustion Turbine # 1	72-A-160-S3
EP-4	EU-2	Combustion Turbine # 2	74-A-079-S1-S1
EP-11	EU-9	Combustion Turbine # 1 Diesel Starting Engine	None
EP-13	EU-11	Combustion Turbine #2 Diesel Starting Engine (Dual Stack with EP14)	None
EP-14		Combustion Turbine #2 Diesel starting Engine (Dual stack with EP13)	None
EP-12A	EU-12	Emergency Engine	Exempt
EP-15	EU-15	Non-emergency Natural Gas-fired Engine	19-A-235
EP-16	EU-16	Non-emergency Natural Gas-fired Engine	19-A-236
EP-17	EU-17	Non-emergency Natural Gas-fired Engine	19-A-237
EP-18	EU-18	Emergency Engine	19-A-238
IEU4	IEU4	Gasoline Storage Tank	Exempt

## Insignificant Activities Equipment List

Insignificant Emission Unit Number	Insignificant Emission Unit Description
IEU1	Diesel Storage Tank (East Tank) #1
IEU2	Diesel Storage Tank (West Tank) #2
IEU3	Diesel Fuel Tank (1,000 Gallons)
IEU5	New Oil Tank (10,000 Gallons)
IEU6	Waste Oil Tank (5,000 Gallons)
IEU7	Service Oil Tank (5,000 Gallons)
IEU8	Emergency Generator Belly Tank (660 Gallons)
IEU9	Maintenance Service Water Tank (2,641 Gallons)
IEU10	Urea/DEF Tank (10,000 Gallons)
EU-19	Bath Heater

## II. Plant-Wide Conditions

Facility Name: Central Iowa Power Cooperative – Summit Lake Facility Generating Station  
Permit Number: 99-TV-003R4

Permit conditions are established in accord with 567 Iowa Administrative Code rule 22.108

---

### Permit Duration

The term of this permit is: Five years from permit issuance  
Commencing on: 03/17/2022  
Ending on: 03/16/2027

Amendments, modifications and reopenings of the permit shall be obtained in accordance with 567 Iowa Administrative Code rules 22.110 - 22.114. Permits may be suspended, terminated, or revoked as specified in 567 Iowa Administrative Code Rules 22.115.

---

### Emission Limits

*Unless specified otherwise in the Source Specific Conditions, the following limitations and supporting regulations apply to all emission points at this plant:*

Opacity (visible emissions): 40% opacity  
Authority for Requirement: 567 IAC 23.3(2)"d"

Sulfur Dioxide (SO<sub>2</sub>): 500 parts per million by volume  
Authority for Requirement: 567 IAC 23.3(3)"e"

#### Particulate Matter:

No person shall cause or allow the emission of particulate matter from any source in excess of the emission standards specified in this chapter, except as provided in 567 – Chapter 24. For sources constructed, modified or reconstructed on or after July 21, 1999, the emission of particulate matter from any process shall not exceed an emission standard of 0.1 grain per dry standard cubic foot of exhaust gas, except as provided in 567 – 21.2(455B), 23.1(455B), 23.4(455B) and 567 – Chapter 24.

For sources constructed, modified or reconstructed prior to July 21, 1999, the emission of particulate matter from any process shall not exceed the amount determined from Table I, or amount specified in a permit if based on an emission standard of 0.1 grain per standard cubic foot of exhaust gas or established from standards provided in 23.1(455B) and 23.4(455B).  
Authority for Requirement: 567 IAC 23.3(2)"a"

Fugitive Dust: Attainment and Unclassified Areas - No person shall allow, cause or permit any materials to be handled, transported or stored; or a building, its appurtenances or a construction haul road to be used, constructed, altered repaired or demolished, with the exception of farming operations or dust generated by ordinary travel on unpaved public roads, without taking reasonable precautions to prevent particulate matter in quantities sufficient to create a nuisance, as defined in Iowa Code section 657.1, from becoming airborne. All persons, with the above exceptions, shall take reasonable precautions to prevent the discharge of visible emissions of fugitive dusts beyond the lot line of the property on which the emissions originate. The highway

authority shall be responsible for taking corrective action in those cases where said authority has received complaints of or has actual knowledge of dust conditions which require abatement pursuant to this subrule. Reasonable precautions may include, but not limited to, the following procedures.

1. Use, where practical, of water or chemicals for control of dusts in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land.
2. Application of suitable materials, such as but not limited to asphalt, oil, water or chemicals on unpaved roads, material stockpiles, race tracks and other surfaces which can give rise to airborne dusts.
3. Installation and use of containment or control equipment, to enclose or otherwise limit the emissions resulting from the handling and transfer of dusty materials, such as but not limited to grain, fertilizers or limestone.
4. Covering at all times when in motion, open-bodied vehicles transporting materials likely to give rise to airborne dusts.
5. Prompt removal of earth or other material from paved streets or to which earth or other material has been transported by trucking or earth-moving equipment, erosion by water or other means.

Authority for Requirement: 567 IAC 23.3(2)"c"

---

#### **40 CFR 63 Subpart ZZZZ Requirements**

This facility is of the source category affected by the following federal regulation: National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE NESHAP) [40 CFR Part 63 Subpart ZZZZ]. The affected units are EP-11, EP-13, EP-14, EP-15, EP-16, EP-17.

See Appendix for the link of the Standard.

Authority for Requirements: 40 CFR 63 Subpart ZZZZ

### III. Emission Point-Specific Conditions

Facility Name: Central Iowa Power Cooperative – Summit Lake Facility Generating Station  
Permit Number: 99-TV-003R4

---

#### Emission Point ID Number: EP-3 and EP-4

##### Associated Equipment

EP#	EU#	Emission Unit Description	Maximum Design Capacity	CE#	Control Equipment Description	Permit #
3	1	Combustion Turbine #1	450 mmBtu/hr	NA	NA	72-A-160-S3
4	2	Combustion Turbine #2	450 mmBtu/hr	NA	NA	74-A-079-S1

Raw Material/Fuel: Diesel Fuel or Natural Gas

#### Applicable Requirements

##### Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)

*The emissions from this emission point shall not exceed the levels specified below.*

The following emission limits shall not be exceeded per emission point:

Pollutant: Opacity

Emission Limit(s): 40%<sup>(1)</sup>

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment  
567 IAC 23.3(2) "d"

<sup>(1)</sup>An exceedance of the indicator opacity of "no visible emissions (No VE)" will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM<sub>2.5</sub>)

Emission Limit(s): 5.37 lb/hr

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment

Pollutant: Particulate Matter (PM<sub>10</sub>)

Emission Limit(s): 5.37 lb/hr

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment  
567 IAC 23.3(2) "a"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>) using Liquid Fuel (Diesel)

Emission Limit(s): 2.5 lb/MMBtu

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment  
567 IAC 23.3(3) "b"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>) using Natural Gas

Emission Limit(s): 500 ppmv

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment  
567 IAC 23.3(3) "e"

The following combined emission limits shall not be exceeded for both emission points:

Pollutant: Nitrogen Oxides (NO<sub>x</sub>)

Emission Limit(s): 186 tons/yr

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment

Other:

Cross-State Air Pollution Rule (CSAPR) (a.k.a., Transport Rule (TR))

Pollutant: Nitrogen Oxides (NO<sub>x</sub>) Annual, Nitrogen Oxides (NO<sub>x</sub>) Ozone Season, Sulfur Dioxide (SO<sub>2</sub>) Group 1

Emission Limits: Nitrogen Oxides and Sulfur Dioxide Allowances

Authority for Requirement: 40 CFR Part 97 (See appendix for requirements)

**Operational Requirements**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

All records as required by these permits shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping requirements for these permits shall be:

1. Combustion turbine #1 and combustion turbine #2 shall be fired by natural gas or fuel oil #2 only.
2. The sulfur content of any fuel oil fired in combustion turbine #1 and combustion turbine #2 shall not exceed 0.5 percent by weight.
  - a. Record the sulfur content of any fuel oil fired in combustion turbine #1 and combustion turbine #2, in weight percent.
3. The amount of fuel oil #2 fired in combustion turbine #1 and combustion turbine #2 shall not exceed 2,314,286 gallons per 12-month rolling period per unit.
  - a. Record the amount of fuel oil #2 fired in combustion turbine #1 and combustion turbine #2, in gallons. Calculated and record monthly and 12-month rolling totals for each unit.
4. Combustion turbine #1 and combustion turbine #2 shall be operated in simple cycle mode only.
5. Compliance with the 186 ton/yr NO<sub>x</sub> limit shall be demonstrated by use of a fuel flowmeter and emissions correlation curves for each combustion turbine. The owner or operator shall calculate monthly and 12-month rolling totals. Separate correlation curves



shall be developed for each turbine and each fuel type.

- a. Each fuel flowmeter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, fuel flowmeters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable.
- b. The correlation curves shall conform to 40 CFR Part 75 Appendix E.
- c. NO<sub>x</sub> correlation testing shall be performed once every four operating quarters or twenty calendar quarters, whichever comes first, according to 40 CFR Part 75 Appendix E.
- d. As an alternative to using the correlation curve, the owner or operator may use the following emissions factors for calculating NO<sub>x</sub> emissions:
  - i. Natural gas: 0.7 lb/mmBtu
  - ii. Fuel oil: 1.2 lb/mmBtu

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment

### **Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

EP ID	Stack Height, Feet	Discharge Style	Stack Opening, inches	Stack Temperature, °F	Exhaust Flowrate, SCFM
3	45	Vertical unobstructed	72 x 144	990	262,186
4	45	Vertical unobstructed	72 x 144	990	262,186

Authority for Requirement: DNR Construction Permits listed in Table Associated Equipment

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

### **Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes ☐ No ☒

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP-11, EP-13, EP-14**

### Associated Equipment

Associated Emission Unit ID Numbers: EU-9 and EU-11

Emissions Control Equipment ID Number: None

Emissions Control Equipment Description: NA

Continuous Emissions Monitors ID Numbers: None

Emission Unit Descriptions, Raw Material/Fuel and Rated Capacity are listed in the following table:

*EP=Emission Point, EU=Emission Unit*

EP	EU	Emission Unit Description	Raw Material	Rated Capacity
EP-11	EU-9	Combustion Turbine # 1 Diesel Starting Engine	Diesel Fuel	800 hp
EP-13	EU-11	Combustion Turbine #2 Diesel Starting Engine (Dual Stack with EP14)	Diesel Fuel	635 hp
EP-14		Combustion Turbine #2 Diesel starting Engine (Dual stack with EP13)	Diesel Fuel	

### **Applicable Requirements**

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40%

Authority for Requirement: 567 IAC 23.3(2) "d"

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: 567 IAC 23.3(2) "a"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)

Emission Limit(s): 2.5 lb/MMBtu

Authority for Requirement: 567 IAC 23.3(3) "b"

#### **Operational Limits & Requirements**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

#### **Operating Limits**

Hours of Operation:

The Combustion Turbine No.1 and Combustion Turbine No 2, Diesel Starting Engines shall not operate for more than 500 hours per year base on a twelve-month period rolled monthly. Hours of operation shall be recorded monthly and the records shall be maintained for five years.

Authority for Requirement: 567 IAC 22.108(14)

## **Reporting and Recordkeeping**

*All records as required by this permit shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the DNR. Records shall be legible and maintained in an orderly manner.*

The facility shall monitor the percent of sulfur in the diesel fuel as delivered to accurately track the SO<sub>2</sub> emissions. The amount of fuel purchased and the sulfur content shall be used to calculate the overall sulfur content of all the fuel purchased on a rolling twelve-month average. The sulfur content shall be used to calculate the actual SO<sub>2</sub> emissions. The sulfur content can be vendor supplied or facility generated.

Authority for Requirement: 567 IAC 22.108(4)

## **NSPS and NESHAP Requirements**

The start engines are subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(1)(iii) this black start engine, located at an area source, is an existing stationary RICE as it was constructed prior to June 12, 2006.

### Operation and Maintenance Requirements 40 CFR 63.6603, 63.6625, 63.6640 and Tables 2d and 6 to Subpart ZZZZ

1. Change oil and filter every 500 hours of operation or annually, whichever comes first. (See 63.6625(i) for the oil analysis option to extend time frame of requirements.)
2. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first, and replace as necessary.
3. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.
4. Operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
5. Minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes.

### Recordkeeping Requirements 40 CFR 63.6655

1. Keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your maintenance plan.
2. Comply with applicable recordkeeping requirements in 40 CFR 63.6655.

Notification and Reporting Requirements 40 CFR 63.6645, 63.6650 and Table 2d to Subpart ZZZZ

1. An initial notification is not required per 40 CFR 63.6645(a)(5).
2. Comply with applicable notification requirements in 40 CFR 63.6645 and reporting requirements in 40 CFR 63.6650.

Authority for Requirements: 40 CFR 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

### **Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes ☐ No ☒

Authority for Requirement: 567 IAC 22.108(3)

## **Emission Point ID Number: EP-12A**

### Associated Equipment

Associated Emission Unit ID Numbers (if multiple units vent thru this EP): 12

Emissions Control Equipment ID Number: N/A

Emissions Control Equipment Description: N/A

Continuous Emissions Monitors ID Numbers: N/A

---

Emission Unit vented through this Emission Point: 18

Emission Unit Description: Emergency Engine

Raw Material/Fuel: Natural Gas

Rated Capacity: 225 hp

### Applicable Requirements

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40%<sup>(1)</sup>

Authority for Requirement: 567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of 25% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM)

Emission Limit(s): 0.1 gr/dscf

Authority for Requirement: 567 IAC 23.3(2)"b"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)

Emission Limit(s): 500 ppmv

Authority for Requirement: 567 IAC 23.3(3)"e"

#### **Operating Requirements & Associated Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

### **NESHAP Requirements**

This emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE).

According to 40 CFR 63.6590(a)(2)(iii), this emergency engine, located at an area source, is a new stationary RICE as it was constructed on or after June 12, 2006.

According to 40 CFR 63.6590(c)(1), a new stationary RICE located at an area source of HAP emissions must meet the requirements of Part 63 by meeting the requirements of 40 CFR part 60 subpart JJJJ for spark ignition engines. No further requirements apply for this engine under Part 63.

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

### **NSPS Requirements**

This emergency engine is not subject to 40 CFR 60 Subpart JJJJ – Standards of Performance for Stationary Spark Internal Combustion Engines. According to 40 CFR 60.4230(a)(4)(iv), this emergency engine, is not subject to Subpart JJJJ as it was not manufactured on or after January 1, 2009 and has not been modified or reconstructed after June 12, 2006 – 40 CFR 60.4230(a)(5).

Authority for Requirement: 40 CFR Part 60 Subpart JJJJ  
567 IAC 23.1(2)"zzzz"

### **Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes ☐ No ☒

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Number: 15, 16 & 17

### Associated Equipment

**Table: Natural Gas Engines.**

EP#	EU#	Emission Unit Description	Maximum Design Capacity	CE#	Control Equipment Description	Permit #
15	15	Non-emergency Natural Gas-fired Engine	18,817 kW	15a, 15b	Oxidation catalyst, Selective catalytic reduction	19-A-235
16	16	Non-emergency Natural Gas-fired Engine	18,817 kW	16a, 16b	Oxidation catalyst, Selective catalytic reduction	19-A-236
17	17	Non-emergency Natural Gas-fired Engine	18,817 kW	17a, 17b	Oxidation catalyst, Selective catalytic reduction	19-A-237

Raw Material/Fuel: Natural Gas

Applicable Requirements

### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The following emission limits shall not be exceeded per emission point:*

Pollutant: Opacity

Emission Limit(s): 40%<sup>(1)</sup>

Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of 25% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

Pollutant: Particulate Matter (PM<sub>2.5</sub>)

Emission Limit(s): 3.21 lb/hr

Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines

Pollutant: Particulate Matter (PM<sub>10</sub>)  
Emission Limit(s): 3.21 lb/hr  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines

Pollutant: Particulate Matter (PM)  
Emission Limit(s): 0.1 gr/dscf  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
567 IAC 23.3(2)"b"

Pollutant: Sulfur Dioxide (SO<sub>2</sub>)  
Emission Limit(s): 500 ppmv  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
567 IAC 23.3(3)"e"

Pollutant: Nitrogen Oxides (NO<sub>x</sub>)  
Emission Limit(s): 2.47 lb/hr  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines

Pollutant: Nitrogen Oxides (NO<sub>x</sub>) = NMHC  
Emission Limit(s): 1.0 g/HP-hr or 82 ppmvd @15% O<sub>2</sub>  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
23.1(2)"zzz"

Pollutant: Carbon Monoxide (CO)  
Emission Limit(s): 5.02 lb/hr  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
23.1(2)"zzz"

Pollutant: Volatile Organic Compounds (VOC)  
Emission Limit(s): 6.47 lb/hr  
Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines  
23.1(2)"zzz"

### **Operating Requirements & Associated Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

All records as required by these permits shall be kept on-site for a minimum of five (5) years and shall be available for inspection by the Department. Records shall be legible and maintained in an orderly manner. The operating requirements and associated recordkeeping requirements for these permits shall be:

1. Engines EU15, EU16 and EU17 shall be fired by natural gas only.
2. The owner or operator shall keep a maintenance plan and records according to 40 CFR §60.4243(b)(2)(ii).



3. The owner or operator shall submit notifications, reports and recordkeeping according to 40 CFR §60.4245.
4. The owner or operator shall maintain the inlet temperature to oxidation catalysts CE15a, CE16a and CE17a between 450 and 1350 degrees F, excluding startup and shutdown.
  - a. Monitor and record the inlet temperature to oxidation catalysts CE15a, CE16a and CE17a on a continuous basis.
  - b. If the inlet temperature deviates outside the range required, then record the time, date and actions taken to correct the situation and when the inlet temperature is back in the range required.
5. The owner or operator shall maintain the inlet temperature to selective catalytic reduction systems CE15b, CE16b and CE17b between 430 and 900 degrees F, excluding startup and shutdown.
  - a. Monitor and record the inlet temperature to selective catalytic reduction systems CE15b, CE16b and CE17b on a continuous basis.
  - b. If the inlet temperature deviates outside the range required, then record the time, date and actions taken to correct the situation and when the inlet temperature is back in the range required.
6. The owner or operator shall maintain the oxidation catalysts and the selective catalytic reduction systems according to the manufacturer's specifications and maintenance schedule. The owner or operator shall maintain a log of all maintenance and inspection activities performed on the oxidation catalysts and the selective catalytic reduction systems. This log shall include, but is not necessarily limited to:
  - a. The date and time any inspection and/or maintenance was performed on the oxidation catalysts and the selective catalytic reduction systems;
  - b. Any issues identified during the inspection and the date each issue was resolved;
  - c. Any issues addressed during the maintenance activities and the date each issue was resolved; and
  - d. Identification of the staff member performing the maintenance or inspection.

Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines

### **NESHAP Requirements**

The non-emergency engines are subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(2)(iii), the engines, located at an area source, are new stationary RICE as each was constructed on or after June 12, 2006.

According to 40 CFR 63.6590(c)(1), a new stationary RICE located at an area source of HAP emissions must meet the requirements of Part 63 by meeting the requirements of 40 CFR part 60 subpart JJJJ for spark ignition engines. No further requirements apply for this engine under Part 63.

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

### **NSPS Requirements**

These emission units are subject to 40 CFR 60 Subparts A - General Provisions and JJJJ Standards of Performance for Spark Ignition Internal Combustion Engines.

#### **Operating Limits**

1. In accordance with 40 CFR§60.4243(e), the owner or operator may operate EU-15, EU-16, and EU-17 using propane for a maximum of one hundred (100) hours per year, each, as an alternative fuel solely during emergency operations but must keep records of such use. If propane is used for more than one hundred (100) hours per year and the engines are not certified to the emission standards when using propane, the owner or operator is required to conduct a performance test to demonstrate compliance with the emission standards of 40 CFR §60.4233.
2. The owner or operator shall keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test and conduct subsequent performance testing every 8,760 hours or 3 years, whichever comes first, thereafter to demonstrate compliance. Compliance with the 40 CFR 60 Subpart JJJJ limits shall be demonstrated according to the methods in 40 CFR §60.4244.
3. It is expected that air-to-fuel ratio controllers will be used with the operation of three-way catalysts/non-selective catalytic reduction. The AFR controller must be maintained and operated appropriately in order to ensure proper operation of the engine and control device to minimize emissions at all times per 40 CFR §60.4243(g).
4. The owner or operator shall meet all applicable compliance requirements per 40 CFR §60.4243 not specifically listed in this permit.

#### **Reporting & Recordkeeping**

1. In accordance with 40 CFR§60.4245(a), the owner or operator shall keep records of the following information regarding EU-15, EU-16, and EU-17:
  - a. All notifications submitted to comply with NSPS Subpart JJJJ and all documentation supporting any notification.
  - b. Maintenance conducted on each engine.

- c. Documentation that each engine is meets the emission standards.
2. The owner or operator shall follow all other applicable notification, reporting, and recordkeeping requirements of 40 CFR§60.4245.

Authority for Requirement: 40 CFR Part 60 Subpart JJJJ  
567 IAC 23.1(2)"zzz"

**Emission Point Characteristics**

*The emission points shall conform to the specifications listed below.*

EP ID	Stack Height, Feet	Discharge Style	Stack Opening, inches	Stack Temperature, °F	Exhaust Flowrate, SCFM
15	75	Vertical unobstructed	63	690	55,581
16	75	Vertical unobstructed	63	690	55,581
17	75	Vertical unobstructed	63	690	55,581

Authority for Requirement: DNR Construction Permits listed in Table: Natural Gas Engines

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

## **Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements for each emission point listed below.*

### **Stack Testing:**

Pollutant - NO<sub>x</sub>

Stack Test to be Completed: Every 8,760 operating hours or every three years whichever occurs first; the last test was completed 3/16/21-3/18/21.

Test Method - 40 CFR 60, Appendix A, Method 7E

Authority for Requirement - DNR Construction Permits listed in Table: Natural Gas Engines

40 CFR 60 Subpart JJJJ

Pollutant - CO

Stack Test to be Completed: Every 8,760 operating hours or every three years whichever occurs first; the last test was completed 3/16/21-3/18/21.

Test Method - 40 CFR 60, Appendix A, Method 10

Authority for Requirement - DNR Construction Permits listed in Table: Natural Gas Engines

40 CFR 60 Subpart JJJJ

Pollutant - VOC

Stack Test to be Completed: Every 8,760 operating hours or every three years whichever occurs first; the last test was completed 3/16/21-3/18/21.

Test Method - 40 CFR 63, Appendix A, Method 320 or 40 CFR 60, Appendix A, Method 18

Authority for Requirement - DNR Construction Permits listed in Table: Natural Gas Engines

40 CFR 60 Subpart JJJJ

*The owner of this equipment or the owner's authorized agent shall provide written notice to the Director, not less than 30 days before a required stack test or performance evaluation of a continuous emission monitor. Results of the test shall be submitted in writing to the Director in the form of a comprehensive report within 6 weeks of the completion of the testing. 567 IAC 25.1(7)*

**Agency Approved Operation & Maintenance Plan Required?**

Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?**

Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?**

Yes ☐ No ☒

The ZZZZ NESHAP has CAM equivalent monitoring.

Authority for Requirement: 567 IAC 22.108(3)

## Emission Point ID Number: EP-18

### Associated Equipment

Associated Emission Unit ID Numbers (if multiple units vent thru this EP): 18

Emissions Control Equipment ID Number: N/A

Emissions Control Equipment Description: N/A

Continuous Emissions Monitors ID Numbers: N/A

---

Emission Unit vented through this Emission Point: 18

Emission Unit Description: Emergency Engine

Raw Material/Fuel: Ultra Low Sulfur Diesel

Rated Capacity: 689 hp (500 kW)

### Applicable Requirements

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

Pollutant: Opacity

Emission Limit(s): 40%<sup>(1)</sup>

Authority for Requirement: DNR Construction Permit 19-A-238  
567 IAC 23.3(2)"d"

<sup>(1)</sup> An exceedance of the indicator opacity of 25% will require the owner or operator to promptly investigate the emission unit and make corrections to operations or equipment associated with the exceedance. If exceedances continue after the corrections, the Department may require additional proof to demonstrate compliance (e.g., stack testing).

In accordance with §60.4211(c), the engine must be certified by its manufacturer to comply with the emissions standards for emergency engines from §60.4205 (b) and §60.4202 (a)(2). The emission standards that the engine must be certified by the manufacturer to meet are:

Pollutant	Emission Standard	Basis
Particulate Matter (PM)	0.20 grams/kW-hr	§ 89.112 Table 1
NMHC <sup>1</sup> + NOx	4.0 grams/kW-hr	§ 89.112 Table 1
Carbon Monoxide (CO)	3.5 grams/kW-hr	§ 89.112 Table 1
Opacity – acceleration mode	20%	§ 89.113 (a)(1)
Opacity – lugging mode	15%	§ 89.113 (a)(2)
Opacity – peaks in acceleration or lugging modes	50%	§ 89.113 (a)(3)

(1) Non-methane hydrocarbon

In accordance with §60.4211(c), the owner or operator must comply with the required NSPS emissions standards by purchasing an engine certified by its manufacturer to meet the applicable emission standards for the same model year and engine power. The engine must be installed and configured to the manufacturer's specifications. Provided these requirements are satisfied, no further demonstration of compliance with the emission standards from §60.4205 (b) and §60.4202 (a)(2) is required. However, if the engine is not installed, configured, operated, and maintained according to the manufacturer's emission-related written instructions, a compliance demonstration is required in accordance with §60.4211(g).

### **Operating Requirements & Associated Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

1. This engine is limited to operating a maximum of 500 hours in any rolling 12-month period.
2. This engine is limited to operate as an emergency stationary internal combustion engine as defined in §60.4219 and in accordance with §60.4211(f). There is no time limit on the use of the engine in emergency situations provided that the annual hourly limit established in Condition 5.A. is not exceeded. In accordance with §60.4211(f)(2), the engine is limited to operate a maximum of 100 hours per year for maintenance checks and readiness testing.
  - a. In accordance with §60.4211(f)(3), the engine is also allowed to operate up to 50 hours per year in non-emergency situations, but the 50 hours are counted toward the 100 hours provided for maintenance and testing. The 50 hours per year for non-emergency operation cannot be used for peak shaving or non-emergency demand response or to generate income for the facility to supply power to the electric grid or otherwise supply non-emergency power as part of a financial arrangement with another entity.
3. In accordance with §60.4209(a), the engine shall be equipped with a non-resettable hour meter.
4. The owner or operator shall maintain the following monthly records:
  - a. the number of hours that the engine operated for maintenance checks and readiness testing;
  - b. the number of hours that the engine operated for allowed non-emergency operations;
  - c. the total number of hours that the engine operated and
  - d. the rolling 12-month total amount of the number of hours that the engine operated.
5. The owner or operator shall maintain the following annual records:

- a. the number of hours that the engine operated for maintenance checks and readiness testing; and
  - b. the number of hours that the engine operated for allowed non-emergency operations.
  - c. the total number of hours that the engine operated for maintenance checks and readiness testing, and allowed non-emergency operations.
6. In accordance with §60.4207(b), the diesel fuel oil burned in this engine shall meet the following specifications from 40 CFR 80.510(b) for nonroad diesel fuel:

Parameter	Limit
Sulfur (S) content	15 ppm (0.0015%) by weight
Minimum cetane index <b>or</b>	40
Maximum aromatic content	35% (by volume)

The owner or operator of the engine shall comply with these requirements listed above by one of the following methods:

- a. have the fuel supplier certify that the fuel delivered meets the definition of non-road diesel fuel as defined in 40 CFR 80.510(b);
  - b. obtain a fuel analysis from the supplier showing the sulfur content and cetane index or aromatic content of the fuel delivered; or
  - c. perform an analysis of the fuel to determine the sulfur content and cetane index or aromatic content of the fuel received.
7. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in §60.4211(g).
8. In accordance with §60.4211(a), this engine shall be operated and maintained in accordance with the manufacturer's emission-related written instructions. The owner or operator may only change emission-related engine settings that are permitted by the manufacturer.

Authority for Requirement: DNR Construction Permit 19-A-238

### **NESHAP Requirements**

This emergency engine is subject to 40 CFR 63 Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE). According to 40 CFR 63.6590(a)(2)(iii), this emergency engine, located at an area source, is a new stationary RICE as it was constructed on or after June 12, 2006.

According to 40 CFR 63.6590(c)(1), a new stationary RICE located at an area source of HAP emissions must meet the requirements of Part 63 by meeting the requirements of 40 CFR part 60 subpart IIII for compression ignition engines. No further requirements apply for this engine under Part 63.

Authority for Requirement: 40 CFR Part 63 Subpart ZZZZ  
567 IAC 23.1(4)"cz"

### **NSPS Requirements**

This emergency engine is subject to 40 CFR 60 Subpart IIII – New Source Performance Standards for Stationary Compression Ignition Internal Combustion Engines.

Authority for Requirement: 40 CFR Part 60 Subpart IIII

### **Emission Point Characteristics**

*The emission point shall conform to the specifications listed below.*

Stack Height, (ft, from the ground): 49.5

Stack Opening, (inches, dia.): 8

Exhaust Flow Rate (scfm): 1,513

Exhaust Temperature (°F): 916

Discharge Style: Vertical Unobstructed

Authority for Requirement: DNR Construction Permit 19-A-238

The temperature and flowrate are intended to be representative and characteristic of the design of the permitted emission point. The Department recognizes that the temperature and flow rate may vary with changes in the process and ambient conditions. If it is determined that any of the emission point characteristics above are different than the values stated, the owner or operator shall submit a request either by electronic mail or written correspondence to the Department within thirty (30) days of the discovery to determine if a permit amendment is required, or submit a permit application requesting to amend the permit.

### **Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?** Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?** Yes ☐ No ☒

Authority for Requirement: 567 IAC 22.108(3)



## **Emission Point ID Number: IEU4**

### Associated Equipment

Associated Emission Unit ID Numbers (if multiple units vent thru this EP): IEU4

Emissions Control Equipment ID Number: N/A

Emissions Control Equipment Description: N/A

Continuous Emissions Monitors ID Numbers: N/A

---

Emission Unit vented through this Emission Point: 18

Emission Unit Description: Gasoline Storage Tank

Raw Material/Fuel: Gasoline

Rated Capacity: 1,500 Gallons

### Applicable Requirements

#### **Emission Limits (lb./hr, gr./dscf, lb./MMBtu, % opacity, etc.)**

*The emissions from this emission point shall not exceed the levels specified below.*

None at this time.

#### **Operating Requirements & Associated Recordkeeping**

*The owner/operator of this equipment shall comply with the operational limits and requirements listed below.*

#### **NESHAP Requirements**

The tank is subject to 40 CFR 63 Subpart CCCCCC - National Emission Standards for Hazardous Air Pollutants for Source Category: Gasoline Dispensing Facilities. According to 40 CFR 63.11112(d) this storage tank, located at an area source, is an existing storage tank as it was constructed prior to November 9, 2006.

§63.11116 Requirements for facilities with monthly throughput of less than 10,000 gallons of gasoline.

1. You must not allow gasoline to be handled in a manner that would result in vapor releases to the atmosphere for extended periods of time. Measures to be taken include, but are not limited to, the following:
  - a) Minimize gasoline spills;
  - b) Clean up spills as expeditiously as practicable;
  - c) Cover all open gasoline containers and all gasoline storage tank fill-pipes with a gasketed seal when not in use;
  - d) Minimize gasoline sent to open waste collection systems that collect and transport gasoline to reclamation and recycling devices, such as oil/water separators.

2. You are not required to submit notifications or reports as specified in §63.11125, §63.11126, or subpart A of this part, but you must have records available within 24 hours of a request by the Administrator to document your gasoline throughput.
3. You must comply with the requirements of this subpart by the applicable dates specified in §63.11113.
4. Portable gasoline containers that meet the requirements of 40 CFR part 59, subpart F, are considered acceptable for compliance with paragraph (a)(3) of this section.

**Monitoring Requirements**

*The owner/operator of this equipment shall comply with the monitoring requirements listed below.*

**Agency Approved Operation & Maintenance Plan Required?**      Yes ☐ No ☒

**Facility Maintained Operation & Maintenance Plan Required?**      Yes ☐ No ☒

**Compliance Assurance Monitoring (CAM) Plan Required?**      Yes ☐ No ☒

Authority for Requirement: 567 IAC 22.108(3)

## **IV. General Conditions**

This permit is issued under the authority of the Iowa Code subsection 455B.133(8) and in accordance with 567 Iowa Administrative Code chapter 22.

### **G1. Duty to Comply**

1. The permittee must comply with all conditions of the Title V permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for a permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. *567 IAC 22.108(9)"a"*
2. Any compliance schedule shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based. *567 IAC 22.105 (2)"h"(3)*
3. Where an applicable requirement of the Act is more stringent than an applicable requirement of regulations promulgated under Title IV of the Act, both provisions shall be enforceable by the administrator and are incorporated into this permit. *567 IAC 22.108 (1)"b"*
4. Unless specified as either "state enforceable only" or "local program enforceable only", all terms and conditions in the permit, including provisions to limit a source's potential to emit, are enforceable by the administrator and citizens under the Act. *567 IAC 22.108 (14)*
5. It shall not be a defense for a permittee, in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. *567 IAC 22.108 (9)"b"*
6. For applicable requirements with which the permittee is in compliance, the permittee shall continue to comply with such requirements. For applicable requirements that will become effective during the permit term, the permittee shall meet such requirements on a timely basis. *567 IAC 22.108(15)"c"*

### **G2. Permit Expiration**

1. Except as provided in rule 567—22.104(455B), permit expiration terminates a source's right to operate unless a timely and complete application for renewal has been submitted in accordance with rule 567—22.105(455B). *567 IAC 22.116(2)*
2. To be considered timely, the owner, operator, or designated representative (where applicable) of each source required to obtain a Title V permit shall submit on forms or electronic format specified by the Department to the Air Quality Bureau, Iowa Department of Natural Resources, Air Quality Bureau, Wallace State Office Building, 502 E 9th St., Des Moines, IA 50319-0034, two copies (three if your facility is located in Linn or Polk county) of a complete permit application, at least 6 months but not more than 18 months prior to the date of permit expiration. An additional copy must also be sent to U.S. EPA Region VII, Attention: Chief of Air Permitting & Standards Branch, 11201 Renner Blvd., Lenexa, KS 66219. Additional copies to local programs or EPA are not required for application materials submitted through the electronic format specified by the Department. The application must include all emission points, emission units, air pollution control equipment, and monitoring devices at the facility. All emissions generating activities, including fugitive emissions, must be included. The definition of a complete application is as indicated in 567 IAC 22.105(2). *567 IAC 22.105*

### **G3. Certification Requirement for Title V Related Documents**

Any application, report, compliance certification or other document submitted pursuant to this permit shall contain certification by a responsible official of truth, accuracy, and completeness. All certifications shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. *567 IAC 22.107 (4)*

#### **G4. Annual Compliance Certification**

By March 31 of each year, the permittee shall submit compliance certifications for the previous calendar year. The certifications shall include descriptions of means to monitor the compliance status of all emissions sources including emissions limitations, standards, and work practices in accordance with applicable requirements. The certification for a source shall include the identification of each term or condition of the permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, currently and over the reporting period consistent with all applicable department rules. For sources determined not to be in compliance at the time of compliance certification, a compliance schedule shall be submitted which provides for periodic progress reports, dates for achieving activities, milestones, and an explanation of why any dates were missed and preventive or corrective measures. The compliance certification shall be submitted to the administrator, director, and the appropriate DNR Field office. *567 IAC 22.108 (15)"e"*

#### **G5. Semi-Annual Monitoring Report**

By March 31 and September 30 of each year, the permittee shall submit a report of any monitoring required under this permit for the 6 month periods of July 1 to December 31 and January 1 to June 30, respectively. All instances of deviations from permit requirements must be clearly identified in these reports, and the report must be signed by a responsible official, consistent with 567 IAC 22.107(4). The semi-annual monitoring report shall be submitted to the director and the appropriate DNR Field office. *567 IAC 22.108 (5)*

#### **G6. Annual Fee**

1. The permittee is required under subrule 567 IAC 22.106 to pay an annual fee based on the total tons of actual emissions of each regulated air pollutant. Beginning July 1, 1996, Title V operating permit fees will be paid on July 1 of each year. The fee shall be based on emissions for the previous calendar year.
2. The fee amount shall be calculated based on the first 4,000 tons of each regulated air pollutant emitted each year. The fee to be charged per ton of pollutant will be available from the department by June 1 of each year. The Responsible Official will be advised of any change in the annual fee per ton of pollutant.
3. The emissions inventory shall be submitted annually by March 31 with forms specified by the department documenting actual emissions for the previous calendar year.
4. The fee shall be submitted annually by July 1 with forms specified by the department.
5. If there are any changes to the emission calculation form, the department shall make revised forms available to the public by January 1. If revised forms are not available by January 1, forms from the previous year may be used and the year of emissions documented changed. The department shall calculate the total statewide Title V emissions for the prior calendar year and make this information available to the public no later than April 30 of each year.
6. Phase I acid rain affected units under section 404 of the Act shall not be required to pay a fee for emissions which occur during the years 1993 through 1999 inclusive.
7. The fee for a portable emissions unit or stationary source which operates both in Iowa and out of state shall be calculated only for emissions from the source while operating in Iowa.
8. Failure to pay the appropriate Title V fee represents cause for revocation of the Title V permit as indicated in 567 IAC 22.115(1)"d".

#### **G7. Inspection of Premises, Records, Equipment, Methods and Discharges**

Upon presentation of proper credentials and any other documents as may be required by law, the permittee shall allow the director or the director's authorized representative to:

1. Enter upon the permittee's premises where a Title V source is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
3. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
4. Sample or monitor, at reasonable times, substances or parameters for the purpose of ensuring compliance with the permit or other applicable requirements. *567 IAC 22.108 (15)"b"*

#### **G8. Duty to Provide Information**

The permittee shall furnish to the director, within a reasonable time, any information that the director may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee also shall furnish to the director copies of records required to be kept by the permit, or for information claimed to be confidential, the permittee shall furnish such records directly to the administrator of EPA along with a claim of confidentiality. *567 IAC 22.108 (9)"e"*

#### **G9. General Maintenance and Repair Duties**

The owner or operator of any air emission source or control equipment shall:

1. Maintain and operate the equipment or control equipment at all times in a manner consistent with good practice for minimizing emissions.
2. Remedy any cause of excess emissions in an expeditious manner.
3. Minimize the amount and duration of any excess emission to the maximum extent possible during periods of such emissions. These measures may include but not be limited to the use of clean fuels, production cutbacks, or the use of alternate process units or, in the case of utilities, purchase of electrical power until repairs are completed.
4. Schedule, at a minimum, routine maintenance of equipment or control equipment during periods of process shutdowns to the maximum extent possible. *567 IAC 24.2(1)*

#### **G10. Recordkeeping Requirements for Compliance Monitoring**

1. In addition to any source specific recordkeeping requirements contained in this permit, the permittee shall maintain the following compliance monitoring records, where applicable:

- a. The date, place and time of sampling or measurements
- b. The date the analyses were performed.
- c. The company or entity that performed the analyses.
- d. The analytical techniques or methods used.
- e. The results of such analyses; and
- f. The operating conditions as existing at the time of sampling or measurement.
- g. The records of quality assurance for continuous compliance monitoring systems (including but not limited to quality control activities, audits and calibration drifts.)

2. The permittee shall retain records of all required compliance monitoring data and support information for a period of at least 5 years from the date of compliance monitoring sample, measurement report or application. Support information includes all calibration and maintenance records and all original strip chart recordings for continuous compliance monitoring, and copies of all reports required by the permit.

3. For any source which in its application identified reasonably anticipated alternative operating scenarios, the permittee shall:

- a. Comply with all terms and conditions of this permit specific to each alternative scenario.
- b. Maintain a log at the permitted facility of the scenario under which it is operating.
- c. Consider the permit shield, if provided in this permit, to extend to all terms and conditions under each operating scenario. *567 IAC 22.108(4), 567 IAC 22.108(12)*

**G11. Evidence used in establishing that a violation has or is occurring.**

Notwithstanding any other provisions of these rules, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any provisions herein.

1. Information from the use of the following methods is presumptively credible evidence of whether a violation has occurred at a source:

- a. A monitoring method approved for the source and incorporated in an operating permit pursuant to 567 Chapter 22;
- b. Compliance test methods specified in 567 Chapter 25; or
- c. Testing or monitoring methods approved for the source in a construction permit issued pursuant to 567 Chapter 22.

2. The following testing, monitoring or information gathering methods are presumptively credible testing, monitoring, or information gathering methods:

- a. Any monitoring or testing methods provided in these rules; or
- b. Other testing, monitoring, or information gathering methods that produce information comparable to that produced by any method in subrule 21.5(1) or this subrule. *567 IAC 21.5(1)-567 IAC 21.5(2)*

**G12. Prevention of Accidental Release: Risk Management Plan Notification and Compliance Certification**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Act, the permittee shall notify the department of this requirement. The plan shall be filed with all appropriate authorities by the deadline specified by EPA. A certification that this risk management plan is being properly implemented shall be included in the annual compliance certification of this permit. *567 IAC 22.108(6)*

**G13. Hazardous Release**

The permittee must report any situation involving the actual, imminent, or probable release of a hazardous substance into the atmosphere which, because of the quantity, strength and toxicity of the substance, creates an immediate or potential danger to the public health, safety or to the environment. A verbal report shall be made to the department at (515) 725-8694 and to the local police department or the office of the sheriff of the affected county as soon as possible but not later than six hours after the discovery or onset of the condition. This verbal report must be followed up with a written report as indicated in 567 IAC 131.2(2). *567 IAC Chapter 131-State Only*

**G14. Excess Emissions and Excess Emissions Reporting Requirements**

1. Excess Emissions. Excess emission during a period of startup, shutdown, or cleaning of control equipment is not a violation of the emission standard if the startup, shutdown or cleaning is accomplished expeditiously and in a manner consistent with good practice for minimizing emissions. Cleaning of control equipment which does not require the shutdown of the process equipment shall be limited to one six-minute period per one-hour period. An incident of excess emission (other than an incident during startup, shutdown or cleaning of control equipment) is a violation. If the owner or operator of a source maintains that the incident of excess emission was due to a malfunction, the owner or operator must show that the conditions which caused the

incident of excess emission were not preventable by reasonable maintenance and control measures. Determination of any subsequent enforcement action will be made following review of this report. If excess emissions are occurring, either the control equipment causing the excess emission shall be repaired in an expeditious manner or the process generating the emissions shall be shutdown within a reasonable period of time. An expeditious manner is the time necessary to determine the cause of the excess emissions and to correct it within a reasonable period of time. A reasonable period of time is eight hours plus the period of time required to shut down the process without damaging the process equipment or control equipment. A variance from this subrule may be available as provided for in Iowa Code section 455B.143. In the case of an electric utility, a reasonable period of time is eight hours plus the period of time until comparable generating capacity is available to meet consumer demand with the affected unit out of service, unless, the director shall, upon investigation, reasonably determine that continued operation constitutes an unjustifiable environmental hazard and issue an order that such operation is not in the public interest and require a process shutdown to commence immediately.

## 2. Excess Emissions Reporting

a. Initial Reporting of Excess Emissions. An incident of excess emission (other than an incident of excess emission during a period of startup, shutdown, or cleaning) shall be reported to the appropriate field office of the department within eight hours of, or at the start of the first working day following the onset of the incident. The reporting exemption for an incident of excess emission during startup, shutdown or cleaning does not relieve the owner or operator of a source with continuous monitoring equipment of the obligation of submitting reports required in 567-subrule 25.1(6). An initial report of excess emission is not required for a source with operational continuous monitoring equipment (as specified in 567-subrule 25.1(1) ) if the incident of excess emission continues for less than 30 minutes and does not exceed the applicable emission standard by more than 10 percent or the applicable visible emission standard by more than 10 percent opacity. The initial report may be made by electronic mail (E-mail), in person, or by telephone and shall include as a minimum the following:

- i. The identity of the equipment or source operation from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and expected duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps being taken to remedy the excess emission.
- vi. The steps being taken to limit the excess emission in the interim period.

b. Written Reporting of Excess Emissions. A written report of an incident of excess emission shall be submitted as a follow-up to all required initial reports to the department within seven days of the onset of the upset condition, and shall include as a minimum the following:

- i. The identity of the equipment or source operation point from which the excess emission originated and the associated stack or emission point.
- ii. The estimated quantity of the excess emission.
- iii. The time and duration of the excess emission.
- iv. The cause of the excess emission.
- v. The steps that were taken to remedy and to prevent the recurrence of the incident of excess emission.

- vi. The steps that were taken to limit the excess emission.
- vii. If the owner claims that the excess emission was due to malfunction, documentation to support this claim. *567 IAC 24.1(1)-567 IAC 24.1(4)*

3. Emergency Defense for Excess Emissions. For the purposes of this permit, an "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the permit due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include non-compliance, to the extent caused by improperly designed equipment, lack of preventive maintenance, careless or improper operation or operator error. An emergency constitutes an affirmative defense to an action brought for non-compliance with technology based limitations if it can be demonstrated through properly signed contemporaneous operating logs or other relevant evidence that:

- a. An emergency occurred and that the permittee can identify the cause(s) of the emergency;
- b. The facility at the time was being properly operated;
- c. During the period of the emergency, the permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards or other requirements of the permit; and
- d. The permittee submitted notice of the emergency to the director by certified mail within two working days of the time when the emissions limitations were exceeded due to the emergency. This notice fulfills the requirement of paragraph 22.108(5)"b." – See G15. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

In any enforcement proceeding, the permittee seeking to establish the occurrence of an emergency has the burden of proof. This provision is in addition to any emergency or upset provision contained in any applicable requirement. *567 IAC 22.108(16)*

#### **G15. Permit Deviation Reporting Requirements**

A deviation is any failure to meet a term, condition or applicable requirement in the permit. Reporting requirements for deviations that result in a hazardous release or excess emissions have been indicated above (see G13 and G14). Unless more frequent deviation reporting is specified in the permit, any other deviation shall be documented in the semi-annual monitoring report and the annual compliance certification (see G4 and G5). *567 IAC 22.108(5)"b"*

#### **G16. Notification Requirements for Sources That Become Subject to NSPS and NESHAP Regulations**

During the term of this permit, the permittee must notify the department of any source that becomes subject to a standard or other requirement under 567-subrule 23.1(2) (standards of performance of new stationary sources) or section 111 of the Act; or 567-subrule 23.1(3) (emissions standards for hazardous air pollutants), 567-subrule 23.1(4) (emission standards for hazardous air pollutants for source categories) or section 112 of the Act. This notification shall be submitted in writing to the department pursuant to the notification requirements in 40 CFR Section 60.7, 40 CFR Section 61.07, and/or 40 CFR Section 63.9. *567 IAC 23.1(2), 567 IAC 23.1(3), 567 IAC 23.1(4)*

#### **G17. Requirements for Making Changes to Emission Sources That Do Not Require Title V Permit Modification**



1. Off Permit Changes to a Source. Pursuant to section 502(b)(10) of the CAAA, the permittee may make changes to this installation/facility without revising this permit if:
  - a. The changes are not major modifications under any provision of any program required by section 110 of the Act, modifications under section 111 of the act, modifications under section 112 of the act, or major modifications as defined in 567 IAC Chapter 22.
  - b. The changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions);
  - c. The changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or as total emissions);
  - d. The changes are not subject to any requirement under Title IV of the Act (revisions affecting Title IV permitting are addressed in rules 567—22.140(455B) through 567 - 22.144(455B));
  - e. The changes comply with all applicable requirements.
  - f. For each such change, the permitted source provides to the department and the administrator by certified mail, at least 30 days in advance of the proposed change, a written notification, including the following, which must be attached to the permit by the source, the department and the administrator:
    - i. A brief description of the change within the permitted facility,
    - ii. The date on which the change will occur,
    - iii. Any change in emission as a result of that change,
    - iv. The pollutants emitted subject to the emissions trade
    - v. If the emissions trading provisions of the state implementation plan are invoked, then Title V permit requirements with which the source shall comply; a description of how the emissions increases and decreases will comply with the terms and conditions of the Title V permit.
    - vi. A description of the trading of emissions increases and decreases for the purpose of complying with a federally enforceable emissions cap as specified in and in compliance with the Title V permit; and
    - vii. Any permit term or condition no longer applicable as a result of the change.
2. Such changes do not include changes that would violate applicable requirements or contravene federally enforceable permit terms and conditions that are monitoring (including test methods), record keeping, reporting, or compliance certification requirements. 567 IAC 22.110(2)
3. Notwithstanding any other part of this rule, the director may, upon review of a notice, require a stationary source to apply for a Title V permit if the change does not meet the requirements of subrule 22.110(1). 567 IAC 22.110(3)
4. The permit shield provided in subrule 22.108(18) shall not apply to any change made pursuant to this rule. Compliance with the permit requirements that the source will meet using the emissions trade shall be determined according to requirements of the state implementation plan authorizing the emissions trade. 567 IAC 22.110(4)
5. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading and other similar programs or processes, for changes that are provided for in this permit. 567 IAC 22.108(11)

**G18. Duty to Modify a Title V Permit**

1. Administrative Amendment.

- a. An administrative permit amendment is a permit revision that does any of the following:
  - i. Correct typographical errors
  - ii. Identify a change in the name, address, or telephone number of any person identified in the permit, or provides a similar minor administrative change at the source;
  - iii. Require more frequent monitoring or reporting by the permittee; or
  - iv. Allow for a change in ownership or operational control of a source where the director determines that no other change in the permit is necessary, provided that a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new permittee has been submitted to the director.
- b. The permittee may implement the changes addressed in the request for an administrative amendment immediately upon submittal of the request. The request shall be submitted to the director.
- c. Administrative amendments to portions of permits containing provisions pursuant to Title IV of the Act shall be governed by regulations promulgated by the administrator under Title IV of the Act.

2. Minor Title V Permit Modification.

- a. Minor Title V permit modification procedures may be used only for those permit modifications that satisfy all of the following:
  - i. Do not violate any applicable requirement;
  - ii. Do not involve significant changes to existing monitoring, reporting or recordkeeping requirements in the Title V permit;
  - iii. Do not require or change a case by case determination of an emission limitation or other standard, or an increment analysis;
  - iv. Do not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and that the source has assumed in order to avoid an applicable requirement to which the source would otherwise be subject. Such terms and conditions include any federally enforceable emissions caps which the source would assume to avoid classification as a modification under any provision under Title I of the Act; and an alternative emissions limit approved pursuant to regulations promulgated under section 112(i)(5) of the Act;
  - v. Are not modifications under any provision of Title I of the Act; and
  - vi. Are not required to be processed as significant modification under rule 567 - 22.113(455B).
- b. An application for minor permit revision shall be on the minor Title V modification application form and shall include at least the following:
  - i. A description of the change, the emissions resulting from the change, and any new applicable requirements that will apply if the change occurs;
  - ii. The permittee's suggested draft permit;
  - iii. Certification by a responsible official, pursuant to 567 IAC 22.107(4), that the proposed modification meets the criteria for use of minor permit modification procedures and a request that such procedures be used; and

iv. Completed forms to enable the department to notify the administrator and the affected states as required by 567 IAC 22.107(7).

c. The permittee may make the change proposed in its minor permit modification application immediately after it files the application. After the permittee makes this change and until the director takes any of the actions specified in 567 IAC 22.112(4) "a" to "c", the permittee must comply with both the applicable requirements governing the change and the proposed permit terms and conditions. During this time, the permittee need not comply with the existing permit terms and conditions it seeks to modify. However, if the permittee fails to comply with its proposed permit terms and conditions during this time period, the existing permit terms and conditions it seeks to modify may be enforced against the facility.

### 3. Significant Title V Permit Modification.

Significant Title V modification procedures shall be used for applications requesting Title V permit modifications that do not qualify as minor Title V modifications or as administrative amendments. These include but are not limited to all significant changes in monitoring permit terms, every relaxation of reporting or recordkeeping permit terms, and any change in the method of measuring compliance with existing requirements. Significant Title V modifications shall meet all requirements of 567 IAC Chapter 22, including those for applications, public participation, review by affected states, and review by the administrator, as those requirements that apply to Title V issuance and renewal.

The permittee shall submit an application for a significant permit modification not later than three months after commencing operation of the changed source unless the existing Title V permit would prohibit such construction or change in operation, in which event the operation of the changed source may not commence until the department revises the permit. 567 IAC 22.111-567 IAC 22.113

### **G19. Duty to Obtain Construction Permits**

Unless exempted in 567 IAC 22.1(2) or to meet the parameters established in 567 IAC 22.1(1)"c", the permittee shall not construct, install, reconstruct or alter any equipment, control equipment or anaerobic lagoon without first obtaining a construction permit, or conditional permit, or permit pursuant to rule 567 IAC 22.8, or permits required pursuant to rules 567 IAC 22.4, 567 IAC 22.5, 567 IAC 31.3, and 567 IAC 33.3 as required in 567 IAC 22.1(1). A permit shall be obtained prior to the initiation of construction, installation or alteration of any portion of the stationary source or anaerobic lagoon. *567 IAC 22.1(1)*

### **G20. Asbestos**

The permittee shall comply with 567 IAC 23.1(3)"a", and 567 IAC 23.2(3)"g" when activities involve asbestos mills, surfacing of roadways, manufacturing operations, fabricating, insulating, waste disposal, spraying applications, demolition and renovation operations (*567 IAC 23.1(3)"a"*); training fires and controlled burning of a demolished building (*567 IAC 23.2*).

### **G21. Open Burning**

The permittee is prohibited from conducting open burning, except as provided in 567 IAC 23.2. *567 IAC 23.2 except 23.2(3)"j"; 567 IAC 23.2(3)"j" - State Only*

### **G22. Acid Rain (Title IV) Emissions Allowances**

The permittee shall not exceed any allowances that it holds under Title IV of the Act or the regulations promulgated there under. Annual emissions of sulfur dioxide in excess of the number of allowances to emit sulfur dioxide held by the owners and operators of the unit or the designated representative of the owners and operators is prohibited. Exceedences of applicable emission rates are prohibited. "Held" in this context refers to both those allowances assigned to the owners and operators by USEPA, and those allowances supplementally acquired by the owners and operators. The use of any allowance prior to the year for which it was allocated is prohibited. Contravention of any other provision of the permit is prohibited. *567 IAC 22.108(7)*

### **G23. Stratospheric Ozone and Climate Protection (Title VI) Requirements**

1. The permittee shall comply with the standards for labeling of products using ozone-depleting substances pursuant to 40 CFR Part 82, Subpart E:

- a. All containers in which a class I or class II substance is stored or transported, all products containing a class I substance, and all products directly manufactured with a class I substance must bear the required warning statement if it is being introduced into interstate commerce pursuant to § 82.106.
- b. The placement of the required warning statement must comply with the requirements pursuant to § 82.108.
- c. The form of the label bearing the required warning statement must comply with the requirements pursuant to § 82.110.
- d. No person may modify, remove, or interfere with the required warning statement except as described in § 82.112.

2. The permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for MVACs in Subpart B:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to § 82.156.
- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to § 82.158.
- c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to § 82.161.

- d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with reporting and recordkeeping requirements pursuant to § 82.166. ("MVAC-like appliance" as defined at § 82.152)
  - e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to § 82.156.
  - f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to § 82.166.
3. If the permittee manufactures, transforms, imports, or exports a class I or class II substance, the permittee is subject to all the requirements as specified in 40 CFR part 82, Subpart A, Production and Consumption Controls.
  4. If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant,
  5. The permittee shall be allowed to switch from any ozone-depleting or greenhouse gas generating substances to any alternative that is listed in the Significant New Alternatives Program (SNAP) promulgated pursuant to 40 CFR part 82, Subpart G, Significant New Alternatives Policy Program. *40 CFR part 82*

#### **G24. Permit Reopenings**

1. This permit may be modified, revoked, reopened, and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. *567 IAC 22.108(9)"c"*
2. Additional applicable requirements under the Act become applicable to a major part 70 source with a remaining permit term of 3 or more years. Revisions shall be made as expeditiously as practicable, but not later than 18 months after the promulgation of such standards and regulations.
  - a. Reopening and revision on this ground is not required if the permit has a remaining term of less than three years;
  - b. Reopening and revision on this ground is not required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to 40 CFR 70.4(b)(10)(i) or (ii) as amended to May 15, 2001.
  - c. Reopening and revision on this ground is not required if the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. *567 IAC 22.108(17)"a"*, *567 IAC 22.108(17)"b"*
3. A permit shall be reopened and revised under any of the following circumstances:
  - a. The department receives notice that the administrator has granted a petition for disapproval of a permit pursuant to 40 CFR 70.8(d) as amended to July 21, 1992, provided that the reopening may be stayed pending judicial review of that determination;

- b. The department or the administrator determines that the Title V permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Title V permit;
- c. Additional applicable requirements under the Act become applicable to a Title V source, provided that the reopening on this ground is not required if the permit has a remaining term of less than three years, the effective date of the requirement is later than the date on which the permit is due to expire, or the additional applicable requirements are implemented in a general permit that is applicable to the source and the source receives approval for coverage under that general permit. Such a reopening shall be complete not later than 18 months after promulgation of the applicable requirement.
- d. Additional requirements, including excess emissions requirements, become applicable to a Title IV affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.
- e. The department or the administrator determines that the permit must be revised or revoked to ensure compliance by the source with the applicable requirements. *567 IAC 22.114(1)*

4. Proceedings to reopen and reissue a Title V permit shall follow the procedures applicable to initial permit issuance and shall effect only those parts of the permit for which cause to reopen exists. *567 IAC 22.114(2)*

5. A notice of intent shall be provided to the Title V source at least 30 days in advance of the date the permit is to be reopened, except that the director may provide a shorter time period in the case of an emergency. *567 IAC 22.114(3)*

#### **G25. Permit Shield**

1. The director may expressly include in a Title V permit a provision stating that compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:

- a. Such applicable requirements are included and are specifically identified in the permit; or
- b. The director, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the source, and the permit includes the determination or a concise summary thereof.

2. A Title V permit that does not expressly state that a permit shield exists shall be presumed not to provide such a shield.

3. A permit shield shall not alter or affect the following:

- a. The provisions of Section 303 of the Act (emergency orders), including the authority of the administrator under that section;
- b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
- c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the Act;
- d. The ability of the department or the administrator to obtain information from the facility pursuant to Section 114 of the Act. *567 IAC 22.108 (18)*

#### **G26. Severability**

The provisions of this permit are severable and if any provision or application of any provision is found to be invalid by this department or a court of law, the application of such provision to

other circumstances, and the remainder of this permit, shall not be affected by such finding. 567 IAC 22.108 (8)

**G27. Property Rights**

The permit does not convey any property rights of any sort, or any exclusive privilege. 567 IAC 22.108 (9)"d"

**G28. Transferability**

This permit is not transferable from one source to another. If title to the facility or any part of it is transferred, an administrative amendment to the permit must be sought consistent with the requirements of 567 IAC 22.111(1). 567 IAC 22.111 (1)"d"

**G29. Disclaimer**

No review has been undertaken on the engineering aspects of the equipment or control equipment other than the potential of that equipment for reducing air contaminant emissions.  
*567 IAC 22.3(3)"c"*

**G30. Notification and Reporting Requirements for Stack Tests or Monitor Certification**

The permittee shall notify the department's stack test contact in writing not less than 30 days before a required test or performance evaluation of a continuous emission monitor is performed to determine compliance with applicable requirements of 567 – Chapter 23 or a permit condition. Such notice shall include the time, the place, the name of the person who will conduct the test and other information as required by the department. If the owner or operator does not provide timely notice to the department, the department shall not consider the test results or performance evaluation results to be a valid demonstration of compliance with applicable rules or permit conditions. Upon written request, the department may allow a notification period of less than 30 days. At the department's request, a pretest meeting shall be held not later than 15 days prior to conducting the compliance demonstration. A testing protocol shall be submitted to the department no later than 15 days before the owner or operator conducts the compliance demonstration. A representative of the department shall be permitted to witness the tests. Results of the tests shall be submitted in writing to the department's stack test contact in the form of a comprehensive report within six weeks of the completion of the testing. Compliance tests conducted pursuant to this permit shall be conducted with the source operating in a normal manner at its maximum continuous output as rated by the equipment manufacturer, or the rate specified by the owner as the maximum production rate at which the source shall be operated. In cases where compliance is to be demonstrated at less than the maximum continuous output as rated by the equipment manufacturer, and it is the owner's intent to limit the capacity to that rating, the owner may submit evidence to the department that the source has been physically altered so that capacity cannot be exceeded, or the department may require additional testing, continuous monitoring, reports of operating levels, or any other information deemed necessary by the department to determine whether such source is in compliance.

Stack test notifications, reports and correspondence shall be sent to:

Stack Test Review Coordinator  
Iowa DNR, Air Quality Bureau  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-9545

Within Polk and Linn Counties, stack test notifications, reports and correspondence shall also be directed to the supervisor of the respective county air pollution program.

*567 IAC 25.1(7)"a", 567 IAC 25.1(9)*

**G31. Prevention of Air Pollution Emergency Episodes**

The permittee shall comply with the provisions of 567 IAC Chapter 26 in the prevention of excessive build-up of air contaminants during air pollution episodes, thereby preventing the occurrence of an emergency due to the effects of these contaminants on the health of persons.  
*567 IAC 26.1(1)*



### **G32. Contacts List**

The current address and phone number for reports and notifications to the EPA administrator is:

Iowa Compliance Officer  
Air Branch  
Enforcement and Compliance Assurance Division  
U.S. EPA Region 7  
11201 Renner Blvd.  
Lenexa, KS 66219  
(913) 551-7020

The current address and phone number for reports and notifications to the department or the Director is:

Chief, Air Quality Bureau  
Iowa Department of Natural Resources  
Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-8200

Reports or notifications to the DNR Field Offices or local programs shall be directed to the supervisor at the appropriate field office or local program. Current addresses and phone numbers are:

#### **Field Office 1**

1101 Commercial Court, Suite 10  
Manchester, IA 52057  
(563) 927-2640

#### **Field Office 2**

2300-15th St., SW  
Mason City, IA 50401  
(641) 424-4073

#### **Field Office 3**

1900 N. Grand Ave.  
Spencer, IA 51301  
(712) 262-4177

#### **Field Office 4**

1401 Sunnyside Lane  
Atlantic, IA 50022  
(712) 243-1934

#### **Field Office 5**

Wallace State Office Building  
502 E 9<sup>th</sup> St.  
Des Moines, IA 50319-0034  
(515) 725-0268

#### **Field Office 6**

1023 West Madison Street  
Washington, IA 52353-1623  
(319) 653-2135

#### **Polk County Public Works Dept.**

Air Quality Division  
5885 NE 14th St.  
Des Moines, IA 50313  
(515) 286-3351

#### **Linn County Public Health**

Air Quality Branch  
1020 6<sup>th</sup> Street SE  
Cedar Rapids, IA 52401  
(319) 892-6000

## V. Appendix

### A. 40 CFR 63 Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

<http://www.ecfr.gov/cgi-bin/text-idx?c=ecfr;rgn=div6;view=text;node=40%3A14.0.1.1.1.1;idno=40;sid=e94dcfde4a04b27290c445a56e635e58;cc=ecfr>

### B. Transport Rule (TR) Trading Program Title V Requirements

#### Description of TR Monitoring Provisions

The TR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following table(s). These unit(s) are subject to the requirements for the TR NO<sub>x</sub> Annual Trading Program, TR NO<sub>x</sub> Ozone Season Group 2 Trading Program and TR SO<sub>2</sub> Group 1 Trading Program.

Unit ID: 1G (ORIS Code: 1206) Central Iowa Power Cooperative – Summit Lake Facility Generating Station					
Parameter	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR part 75, subpart B (for SO <sub>2</sub> monitoring) and 40 CFR part 75, subpart H (for NO <sub>x</sub> monitoring)	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E	Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19	EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E
SO <sub>2</sub>			-----	X	
NO <sub>x</sub>		-----		X	
Heat input			-----	X	

Unit ID: 2G (ORIS Code: 1206) Central Iowa Power Cooperative – Summit Lake Facility Generating Station					
Parameter	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR part 75, subpart B (for SO <sub>2</sub> monitoring) and 40 CFR part 75, subpart H (for NO <sub>x</sub> monitoring)	Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR part 75, appendix D	Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR part 75, appendix E	Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19	EPA-approved alternative monitoring system requirements pursuant to 40 CFR part 75, subpart E
SO <sub>2</sub>			-----	X	
NO <sub>x</sub>		-----		X	
Heat input			-----	X	

1. The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR 97.430 through 97.435 (TR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.835 (TR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and 97.630 through 97.635 (TR SO<sub>2</sub> Group 1 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable TR trading programs.

2. Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/monitoring-plans-part-75-sources#monMethod>.

3. Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR part 75, subpart E and 40 CFR 75.66 and 97.435 (TR NO<sub>x</sub> Annual Trading Program), 97.835 (TR NO<sub>x</sub> Ozone Season Group 2 Trading Program) and/or 97.635 (TR SO<sub>2</sub> Group 1 Trading Program). The Administrator's response approving or disapproving any petition

for an alternative monitoring system is available on the EPA's website at <http://www.epa.gov/airmarkets/part-75-petition-responses>.

4. Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR 97.430 through 97.434 (TR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.834 (TR NO<sub>x</sub> Ozone Season Group 2 Trading Program) and/or 97.630 through 97.634 (TR SO<sub>2</sub> Group 1 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR 75.66 and 97.435 (TR NO<sub>x</sub> Annual Trading Program), 97.835 (TR NO<sub>x</sub> Ozone Season Group 2 Trading Program) and/or 97.635 (TR SO<sub>2</sub> Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on EPA's website at <http://www.epa.gov/airmarkets/part-75-petition-responses>.

5. The descriptions of monitoring applicable to the unit included above meet the requirement of 40 CFR 97.430 through 97.434 (TR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.834 (TR NO<sub>x</sub> Ozone Season Group 2 Trading Program) and 97.630 through 97.634 (TR SO<sub>2</sub> Group 1 Trading Program), and therefore minor permit modification procedures, in accordance with 40 CFR 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B), may be used to add to or change this unit's monitoring system description.

#### **TR NO<sub>x</sub> Annual Trading Program requirements (40 CFR 97.406)**

##### **(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.

##### **(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each TR NO<sub>x</sub> Annual source and each TR NO<sub>x</sub> Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of TR NO<sub>x</sub> Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the TR NO<sub>x</sub> Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40

CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

**(c) NO<sub>x</sub> emissions requirements.**

**(1) TR NO<sub>x</sub> Annual emissions limitation.**

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO<sub>x</sub> Annual source and each TR NO<sub>x</sub> Annual unit at the source shall hold, in the source's compliance account, TR NO<sub>x</sub> Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all TR NO<sub>x</sub> Annual units at the source.
- (ii). If total NO<sub>x</sub> emissions during a control period in a given year from the TR NO<sub>x</sub> Annual units at a TR NO<sub>x</sub> Annual source are in excess of the TR NO<sub>x</sub> Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
  - (A). The owners and operators of the source and each TR NO<sub>x</sub> Annual unit at the source shall hold the TR NO<sub>x</sub> Annual allowances required for deduction under 40 CFR 97.424(d); and
  - (B). The owners and operators of the source and each TR NO<sub>x</sub> Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.

**(2) TR NO<sub>x</sub> Annual assurance provisions.**

- (i). If total NO<sub>x</sub> emissions during a control period in a given year from all TR NO<sub>x</sub> Annual units at TR NO<sub>x</sub> Annual sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO<sub>x</sub> Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Annual units at TR NO<sub>x</sub> Annual sources in the state for such control period exceed the state assurance level.

- (ii). The owners and operators shall hold the TR NO<sub>x</sub> Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
  - (iii). Total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Annual units at TR NO<sub>x</sub> Annual sources in the State during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the state NO<sub>x</sub> Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).
  - (iv). It shall not be a violation of 40 CFR part 97, subpart AAAAA or of the Clean Air Act if total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Annual units at TR NO<sub>x</sub> Annual sources in the State during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the TR NO<sub>x</sub> Annual units at TR NO<sub>x</sub> Annual sources in the state during a control period exceeds the common designated representative's assurance level.
  - (v). To the extent the owners and operators fail to hold TR NO<sub>x</sub> Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
    - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
    - (B). Each TR NO<sub>x</sub> Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.
- (3) Compliance periods.
- (i). A TR NO<sub>x</sub> Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
  - (ii). A TR NO<sub>x</sub> Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
- (i). A TR NO<sub>x</sub> Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO<sub>x</sub> Annual allowance that was allocated for such control period or a control period in a prior year.
  - (ii). A TR NO<sub>x</sub> Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO<sub>x</sub> Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.

- (5) Allowance Management System requirements. Each TR NO<sub>x</sub> Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart AAAAA.
- (6) Limited authorization. A TR NO<sub>x</sub> Annual allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
  - (i). Such authorization shall only be used in accordance with the TR NO<sub>x</sub> Annual Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A TR NO<sub>x</sub> Annual allowance does not constitute a property right.

**(d) Title V permit revision requirements.**

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO<sub>x</sub> Annual allowances in accordance with 40 CFR part 97, subpart AAAAA.
- (2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**(e) Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each TR NO<sub>x</sub> Annual source and each TR NO<sub>x</sub> Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each TR NO<sub>x</sub> Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart AAAAA.

- (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO<sub>x</sub> Annual Trading Program.
  - (2) The designated representative of a TR NO<sub>x</sub> Annual source and each TR NO<sub>x</sub> Annual unit at the source shall make all submissions required under the TR NO<sub>x</sub> Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.
- (f) Liability.**
- (1) Any provision of the TR NO<sub>x</sub> Annual Trading Program that applies to a TR NO<sub>x</sub> Annual source or the designated representative of a TR NO<sub>x</sub> Annual source shall also apply to the owners and operators of such source and of the TR NO<sub>x</sub> Annual units at the source.
  - (2) Any provision of the TR NO<sub>x</sub> Annual Trading Program that applies to a TR NO<sub>x</sub> Annual unit or the designated representative of a TR NO<sub>x</sub> Annual unit shall also apply to the owners and operators of such unit.
- (g) Effect on other authorities.**
- No provision of the TR NO<sub>x</sub> Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO<sub>x</sub> Annual source or TR NO<sub>x</sub> Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

#### **TR NO<sub>x</sub> Ozone Season Group 2 Trading Program Requirements (40 CFR 97.806)**

**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.813 through 97.818.

**(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each TR NO<sub>x</sub> Ozone Season Group 2 source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.831 (initial monitoring system certification and recertification procedures), 97.832 (monitoring system out-of-control periods), 97.833 (notifications concerning monitoring), 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.830 through 97.835 shall be used to calculate allocations of TR NO<sub>x</sub> Ozone Season Group 2 allowances under 40 CFR 97.811(a)(2) and (b) and 97.812 and to determine compliance with the TR NO<sub>x</sub> Ozone Season Group 2 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are



reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

**(c) NO<sub>x</sub> emissions requirements.**

**(1) TR NO<sub>x</sub> Ozone Season Group 2 emissions limitation.**

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO<sub>x</sub> Ozone Season Group 2 source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, TR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR 97.824(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all TR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (ii). If total NO<sub>x</sub> emissions during a control period in a given year from the TR NO<sub>x</sub> Ozone Season Group 2 units at a TR NO<sub>x</sub> Ozone Season Group 2 source are in excess of the TR NO<sub>x</sub> Ozone Season emissions limitation set forth in paragraph (c)(1)(i) above, then:
  - (A). The owners and operators of the source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold the TR NO<sub>x</sub> Ozone Season Group 2 allowances required for deduction under 40 CFR 97.824(d); and
  - (B). The owners and operators of the source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart EEEEE and the Clean Air Act.

**(2) TR NO<sub>x</sub> Ozone Season Group 2 assurance provisions.**

- (i). If total NO<sub>x</sub> emissions during a control period in a given year from all TR NO<sub>x</sub> Ozone Season Group 2 units at TR NO<sub>x</sub> Ozone Season Group 2 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.825(b), of multiplying—
  - (A). The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for

- such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and
- (B). The amount by which total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Ozone Season Group 2 units at TR NO<sub>x</sub> Ozone Season Group 2 sources in the state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the TR NO<sub>x</sub> Ozone Season Group 2 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (iii). Total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Ozone Season Group 2 units at TR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the State NO<sub>x</sub> Ozone Season Group 2 trading budget under 40 CFR 97.810(a) and the state's variability limit under 40 CFR 97.810(b).
- (iv). It shall not be a violation of 40 CFR part 97, subpart EEEEE or of the Clean Air Act if total NO<sub>x</sub> emissions from all TR NO<sub>x</sub> Ozone Season Group 2 units at TR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the TR NO<sub>x</sub> Ozone Season Group 2 units at TR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceeds the common designated representative's assurance level.
- (v). To the extent the owners and operators fail to hold TR NO<sub>x</sub> Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
- (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
- (B). Each TR NO<sub>x</sub> Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart EEEEE and the Clean Air Act.
- (3) Compliance periods.
- (i). A TR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.
- (ii). A TR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.

- (i). A TR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
- (ii). A TR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each TR NO<sub>x</sub> Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart EEEEE.
- (6) Limited authorization. A TR NO<sub>x</sub> Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
  - (i). Such authorization shall only be used in accordance with the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR part 97, subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A TR NO<sub>x</sub> Ozone Season Group 2 allowance does not constitute a property right.

**(d) Title V permit revision requirements.**

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO<sub>x</sub> Ozone Season Group 2 allowances in accordance with 40 CFR part 97, subpart EEEEE.
- (2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.806(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**(e) Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each TR NO<sub>x</sub> Ozone Season Group 2 source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.

- (i). The certificate of representation under 40 CFR 97.816 for the designated representative for the source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.816 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart EEEEE.
  - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
- (2) The designated representative of a TR NO<sub>x</sub> Ozone Season Group 2 source and each TR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall make all submissions required under the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program, except as provided in 40 CFR 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

**(f) Liability.**

- (1) Any provision of the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a TR NO<sub>x</sub> Ozone Season Group 2 source or the designated representative of a TR NO<sub>x</sub> Ozone Season Group 2 source shall also apply to the owners and operators of such source and of the TR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (2) Any provision of the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a TR NO<sub>x</sub> Ozone Season Group 2 unit or the designated representative of a TR NO<sub>x</sub> Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

**(g) Effect on other authorities.**

No provision of the TR NO<sub>x</sub> Ozone Season Group 2 Trading Program or exemption under 40 CFR 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO<sub>x</sub> Ozone Season Group 2 source or TR NO<sub>x</sub> Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**TR SO<sub>2</sub> Group 1 Trading Program requirements (40 CFR 97.606)**

**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.

**(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each TR SO<sub>2</sub> Group 1 source and each TR SO<sub>2</sub> Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting

data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

- (2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of TR SO<sub>2</sub> Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the TR SO<sub>2</sub> Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

**(c) SO<sub>2</sub> emissions requirements.**

**(1) TR SO<sub>2</sub> Group 1 emissions limitation.**

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO<sub>2</sub> Group 1 source and each TR SO<sub>2</sub> Group 1 unit at the source shall hold, in the source's compliance account, TR SO<sub>2</sub> Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO<sub>2</sub> emissions for such control period from all TR SO<sub>2</sub> Group 1 units at the source.
- (ii). If total SO<sub>2</sub> emissions during a control period in a given year from the TR SO<sub>2</sub> Group 1 units at a TR SO<sub>2</sub> Group 1 source are in excess of the TR SO<sub>2</sub> Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:
  - (A). The owners and operators of the source and each TR SO<sub>2</sub> Group 1 unit at the source shall hold the TR SO<sub>2</sub> Group 1 allowances required for deduction under 40 CFR 97.624(d); and
  - (B). The owners and operators of the source and each TR SO<sub>2</sub> Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR part 97, subpart CCCCC and the Clean Air Act.

**(2) TR SO<sub>2</sub> Group 1 assurance provisions.**

- (i). If total SO<sub>2</sub> emissions during a control period in a given year from all TR SO<sub>2</sub> Group 1 units at TR SO<sub>2</sub> Group 1 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO<sub>2</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in

the assurance account established for the owners and operators of such group) TR SO<sub>2</sub> Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—

- (A). The quotient of the amount by which the common designated representative's share of such SO<sub>2</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such SO<sub>2</sub> emissions exceeds the respective common designated representative's assurance level; and
  - (B). The amount by which total SO<sub>2</sub> emissions from all TR SO<sub>2</sub> Group 1 units at TR SO<sub>2</sub> Group 1 sources in the state for such control period exceed the state assurance level.
- (ii). The owners and operators shall hold the TR SO<sub>2</sub> Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
  - (iii). Total SO<sub>2</sub> emissions from all TR SO<sub>2</sub> Group 1 units at TR SO<sub>2</sub> Group 1 sources in the state during a control period in a given year exceed the state assurance level if such total SO<sub>2</sub> emissions exceed the sum, for such control period, of the state SO<sub>2</sub> Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).
  - (iv). It shall not be a violation of 40 CFR part 97, subpart CCCCC or of the Clean Air Act if total SO<sub>2</sub> emissions from all TR SO<sub>2</sub> Group 1 units at TR SO<sub>2</sub> Group 1 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total SO<sub>2</sub> emissions from the TR SO<sub>2</sub> Group 1 units at TR SO<sub>2</sub> Group 1 sources in the state during a control period exceeds the common designated representative's assurance level.
  - (v). To the extent the owners and operators fail to hold TR SO<sub>2</sub> Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
    - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
    - (B). Each TR SO<sub>2</sub> Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart CCCCC and the Clean Air Act.
- (3) Compliance periods.
- (i). A TR SO<sub>2</sub> Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline

- for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- (ii). A TR SO<sub>2</sub> Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
- (i). A TR SO<sub>2</sub> Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR SO<sub>2</sub> Group 1 allowance that was allocated for such control period or a control period in a prior year.
  - (ii). A TR SO<sub>2</sub> Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR SO<sub>2</sub> Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each TR SO<sub>2</sub> Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart CCCCC.
- (6) Limited authorization. A TR SO<sub>2</sub> Group 1 allowance is a limited authorization to emit one ton of SO<sub>2</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
- (i). Such authorization shall only be used in accordance with the TR SO<sub>2</sub> Group 1 Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR part 97, subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A TR SO<sub>2</sub> Group 1 allowance does not constitute a property right.
- (d) Title V permit revision requirements.**
- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR SO<sub>2</sub> Group 1 allowances in accordance with 40 CFR part 97, subpart CCCCC.
  - (2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR part 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each TR SO<sub>2</sub> Group 1 source and each TR SO<sub>2</sub> Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each TR SO<sub>2</sub> Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart CCCCC.
  - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR SO<sub>2</sub> Group 1 Trading Program.
- (2) The designated representative of a TR SO<sub>2</sub> Group 1 source and each TR SO<sub>2</sub> Group 1 unit at the source shall make all submissions required under the TR SO<sub>2</sub> Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

**(e) Liability.**

- (1) Any provision of the TR SO<sub>2</sub> Group 1 Trading Program that applies to a TR SO<sub>2</sub> Group 1 source or the designated representative of a TR SO<sub>2</sub> Group 1 source shall also apply to the owners and operators of such source and of the TR SO<sub>2</sub> Group 1 units at the source.
- (2) Any provision of the TR SO<sub>2</sub> Group 1 Trading Program that applies to a TR SO<sub>2</sub> Group 1 unit or the designated representative of a TR SO<sub>2</sub> Group 1 unit shall also apply to the owners and operators of such unit.

**(f) Effect on other authorities.**

No provision of the TR SO<sub>2</sub> Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR SO<sub>2</sub> Group 1 source or TR SO<sub>2</sub> Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.